

detection systems and portions of combustible gas-detection systems related to the higher gas concentration levels shall be of the manual-reset type. Combustible gas-detection systems related to the lower gas-concentration level may be of the automatic-reset type.

(iii) A fuel-gas odorant or an automatic gas-detection and alarm system is required in enclosed, continuously manned areas of the facility that are provided with fuel gas. Living quarters and doghouses not containing a gas source and not located in a classified area do not require a gas detection system.

(iv) The District Supervisor may require the installation and maintenance of a gas detector or alarm in any potentially hazardous area.

(v) Fire- and gas-detection systems shall be an approved type, designed and installed in accordance with API RP 14C, API RP 14G, and API RP 14F, Recommended Practice for Design and Installation of Electrical Systems for Offshore Production Platforms.

(c) *General platform operations.* Safety devices shall not be bypassed or blocked out of service unless they are temporarily out of service for startup, maintenance, or testing procedures. Only the minimum number of safety devices shall be taken out of service. Personnel shall monitor the bypassed or blocked out functions until the safety devices are placed back in service. Any safety device that is temporarily out of service shall be flagged by the person taking such device out of service.

[53 FR 10690, Apr. 1, 1988, as amended at 61 FR 60026, Nov. 26, 1996. Redesignated at 63 FR 29479, May 29, 1998, as amended at 64 FR 72794, Dec. 28, 1999; 65 FR 219, Jan. 4, 2000]

§250.1630 Safety-system testing and records.

(a) *Inspection and testing.* Safety-system devices shall be successfully inspected and tested by the lessee at the interval specified below or more frequently if operating conditions warrant. Testing shall be in accordance with API RP 14C, appendix D or for safety-system devices other than those listed in API RP 14C, Appendix D the analysis technique and documentation specified therein shall be utilized for

inspection and testing of these components, and the following:

(1) Safety relief valves on the natural gas feed system for power plant operations such as pressure safety valves shall be inspected and tested for operation at least once every 12 months. These valves shall be either bench tested or equipped to permit testing with an external pressure source.

(2) The following safety devices shall be inspected and tested at least once each calendar month, but at no time shall more than 6 weeks elapse between tests:

(i) All pressure safety high or pressure safety low, and

(ii) All level safety high and level safety low controls.

(3) All pumps for firewater systems shall be inspected and operated weekly.

(4) All fire- (flame, heat, or smoke) and gas-detection systems shall be inspected and tested for operation and recalibrated every 3 months provided that testing can be performed in a non-destructive manner.

(5) Prior to the commencement of production, the lessee shall notify the District Supervisor when the lessee is ready to conduct a preproduction test and inspection of the safety system. The lessee shall also notify the District Supervisor upon commencement of production in order that a complete inspection may be conducted.

(b) *Records.* The lessee shall maintain records for a period of 2 years for each safety device installed. These records shall be maintained by the lessee at the lessee's field office nearest the OCS facility or another location conveniently available to the District Supervisor. These records shall be available for MMS review. The records shall show the present status and history of each safety device, including dates and details of installation, removal, inspection, testing, repairing, adjustments, and reinstallation.

§250.1631 Safety device training.

Prior to engaging in production operations on a lease and periodically thereafter, personnel installing, inspecting, testing, and maintaining safety devices shall be instructed in

§ 250.1632

the safety requirements of the operations to be performed; possible hazards to be encountered; and general safety considerations to be taken to protect personnel, equipment, and the environment. Date and time of safety meetings shall be recorded and available for MMS review.

§ 250.1632 Production rates.

Each sulphur deposit shall be produced at rates that will provide economic development and depletion of the deposit in a manner that would maximize the ultimate recovery of sulphur without resulting in waste (e.g., an undue reduction in the recovery of oil and gas from an associated hydrocarbon accumulation).

§ 250.1633 Production measurement.

(a) *General.* Measurement equipment and security procedures shall be designed, installed, used, maintained, and tested so as to accurately and completely measure the sulphur produced on a lease for purposes of royalty determination.

(b) *Application and approval.* The lessee shall not commence production of sulphur until the Regional Supervisor has approved the method of measurement. The request for approval of the method of measurement shall contain sufficient information to demonstrate to the satisfaction of the Regional Supervisor that the method of measurement meets the requirements of paragraph (a) of this section.

§ 250.1634 Site security.

(a) All locations where sulphur is produced, measured, or stored shall be operated and maintained to ensure against the loss or theft of produced sulphur and to assure accurate and complete measurement of produced sulphur for royalty purposes.

(b) Evidence of mishandling of produced sulphur from an offshore lease, or tampering or falsifying any measurement of production for an offshore lease, shall be reported to the Regional Supervisor as soon as possible but no later than the next business day after discovery of the evidence of mishandling.

30 CFR Ch. II (7-1-00 Edition)

PART 251—GEOLOGICAL AND GEOPHYSICAL (G&G) EXPLORATIONS OF THE OUTER CONTINENTAL SHELF

Sec.

251.1 Definitions.

251.2 Purpose of this part.

251.3 Authority and applicability of this part.

251.4 Types of G&G activities that require permits or Notices.

251.5 Applying for permits or filing Notices.

251.6 Obligations and rights under a permit or a Notice.

251.7 Test drilling activities under a permit.

251.8 Inspection and reporting requirements for activities under a permit.

251.9 Temporarily stopping, canceling, or relinquishing activities approved under a permit.

251.10 Penalties and appeals.

251.11 Submission, inspection, and selection of geological data and information collected under a permit and processed by permittees or third parties.

251.12 Submission, inspection, and selection of geophysical data and information collected under a permit and processed by permittees or third parties.

251.13 Reimbursement for the cost of reproducing data and information and certain processing costs.

251.14 Protecting and disclosing data and information submitted to MMS under a permit.

251.15 Authority for information collection.

AUTHORITY: 43 U.S.C. 1331 *et seq.*

SOURCE: 62 FR 67284, Dec. 24, 1997, unless otherwise noted.

§ 251.1 Definitions.

Terms used in this part have the following meaning:

Act means the Outer Continental Shelf Lands Act (OCSLA), as amended (43 U.S.C. 1331 *et seq.*).

Analyzed geological information means data collected under a permit or a lease that have been analyzed. Analysis may include, but is not limited to, identification of lithologic and fossil content, core analyses, laboratory analyses of physical and chemical properties, well logs or charts, results from formation fluid tests, and descriptions of hydrocarbon occurrences or hazardous conditions.

Archaeological interest means capable of providing scientific or humanistic understanding of past human behavior, cultural adaptation, and related topics